



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX PRE 21.0017X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2021-03-16

Applicant: **Highlight Secure AS**
Nordstranda 923
Fiskå 6143
Norway

Equipment: **Blanking element**

Optional accessory: Safety Plug M25, SP25 with green Viton O-ring Safety Plug M25, SP25 with red Silicone O-ring The plug comes in two length 12 and 17mm, SP25/12 and SP25/17.

Type of Protection: **Ex eb & Ex tb**

Marking: Ex eb IIC Gb
Ex tb IIIC Db

Approved for issue on behalf of the IECEx
Certification Body:

Asle Kaastad

Position:

Certification Manager

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DNV Product Assurance AS
Veritasveien 3
Hovik 1363
Norway





IECEX Certificate of Conformity

Certificate No.: **IECEX PRE 21.0017X**

Page 2 of 3

Date of issue: 2021-03-16

Issue No: 0

Manufacturer: **Highlight Secure AS**
Nordstranda 923
Fiskå 6143
Norway

Additional manufacturing locations: **VP metall AS**
Raufoss Industripark bygn. 53
Raufoss N-2830
Norway

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NO/PRE/ExTR21.0016/00](#)

Quality Assessment Report:

[NO/DNV/QAR21.0002/00](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX PRE 21.0017X**

Page 3 of 3

Date of issue: 2021-03-16

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

This certificate covers Highlight Secure AS blanking element made of brass with a thread size of M25x1.5 and belonging brass nut. It includes two different O-rings, one made of Viton and one made of silicone with two different operating temperatures. The blanking element includes a hank for connection to a safety wire. It is only the Ex requirements for blanking elements that has been assessed and tested in this certificate

Type Identification

Safety Plug M25, SP25 with green Viton O-ring

Safety Plug M25, SP25 with red Silicone O-ring

The plug comes in two length 12 and 17mm, SP25/12 and SP25/17.

Degrees of protection (IP Code)

IP66/67 according to IEC 60079-0

SPECIFIC CONDITIONS OF USE: YES as shown below:

- Operating temperature with the Red, Silicone O-ring is -40°C to +135°C
- Operating temperature of the Green, Viton O-ring is -20°C to +135°C
- The blanking element has to be mounted according to its manual and the enclosure or other suitable devices instructions
- Clearance and creepage distances according to IEC 60079-7 has to be checked after installation, with respect to the blanking elements length into the enclosure
- If mounted in non-metallic enclosure, special caution to earthing has to be taken